



Organisation Chain :	IIT BHUBANESWAR
Tender ID :	2026_IITBR_901764_1
Tender Ref No :	IITBBS/SE/Engg section/55/2025-26
Tender Title :	Electrical works
Corrigendum Type :	Technical Bid

Corrigendum Document Details

Corr.No.	Corrigendum Title	Corrigendum Description	Published Date	Document Name	Doc Size(in KB)
1	Electrical work	Corrigendum Notice	18-Mar-2026 02:19 PM	CN.pdf	981.90



भारतीय प्रौद्योगिकी संस्थान भुवनेश्वर

Indian Institute of Technology Bhubaneswar

अरगूल/Argul, जटनी/Jatni, खुरधा / Khurda, ओडिशा/ Odisha- 752050

दूरभाष/Tel: +91 7138650, 7138700 ; वेब/web: www.iitbbs.ac.in

ENGINEERING SECTION/अभियांत्रिकी अनुभाग

Dt.18.03.2026

CORRIGENDUM NO.1

NIT No. IITBBS/SE/Engg. Section/55/2025-26 dt. 09.03.2026

Name of Work: Repair & Maintenance of fire hydrant system installed at different buildings of IIT Bhubaneswar constructed under Phase-I IIT Bhubaneswar

1. The items mentioned in SI No.1, 2, 4, 5, 6, 7, 8, 9, 10 & 11 of BOQ (Annexure-I) at (Pg-10 to 12 of the Tender) have been revised as per details given below:

SI No.	As mentioned and published in NIT:	Revision tone done
01.	DSR'2025, Item No.27.9.1 HYDRANT SYSTEM Supply, Installation, Testing and Commissioning of 63 mm dia oblique type single headed GM hydrant valve with 63 mm dia instantaneous coupling including rubber gasket, nut & bolt etc. with matching flange and hand wheels complete as per IS 5290, (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT)	DSR'2025, Item No.27.9.1 HYDRANT SYSTEM Supply & fixing single headed Gun Metal internal hydrant valve with instantaneous Gunmetal coupling of 63 mm dia with cast iron wheel ISI Marked confirming to IS 5290 (Type-A) with Blank Gunmetal/Stainless Steel cap & Chain as required. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT)
02	DSR'2025, Item No.27.16.1 Supply and fixing of non-percolating RRL fire hose pipe as per IS:636 of 63 mm dia 15 mtr length .the hose shall be rated for burst pressure of 42 kg/sqcm .hose shall be complete with ISI mark and coupling as per IS 903 bound and rivetted to hose pipe with copper wire. (MAKE-- NEWAGE, AAAG, NEWTECH OR EQUIVALENT)	DSR'2025, Item No.27.16.1 Supply and fixing 63 mm dia, 15 mtr length RRL hose pipe with 63 mm dia male & female couplings (Gunmetal) duly bound with GI wire , rivets etc confirming to IS:636 (Type -A) as required. (MAKE-- NEWAGE, AAAG, NEWTECH OR EQUIVALENT)
04	DSR'2025, Item No.27.12.6 Supply, fitting and fixing of cast iron double flanged type sluice valve as per IS:14846 with ISI mark of pressure rating PN 1.6 including flanges, rubber insertion, nut & bolts etc. complete. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT) 150mm dia	DSR'2025, Item No.27.12.6 Supply, fixing, testing & commissioning of 150 mm size double flanged sluice valve of rating PN 1.6 with non-rising spindle , bronze/gun metal seat, ISI marked complete with nuts, bolts, washers, gaskets and confirming to IS 14846. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT)
05	DSR'2025, Item No.27.12.5 Supply, fitting and fixing of cast iron double flanged type sluice valve as per IS:14846 with ISI mark of pressure rating PN 1.6 including flanges, rubber insertion, nut & bolts etc. complete. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT) 100mm dia	DSR'2025, Item No.27.12.5 Supply, fixing, testing & commissioning of 100 mm size double flanged sluice valve of rating PN 1.6 with non-rising spindle , bronze/gun metal seat, ISI marked complete with nuts, bolts, washers, gaskets and confirming to IS 14846. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT)
06	DSR'2025, Item No.27.12.4 Supply, fitting and fixing of cast iron double flanged type sluice valve as per IS:14846 with ISI mark of pressure rating PN 1.6 including flanges, rubber insertion, nut & bolts etc. complete. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT) 80mm dia	DSR'2025, Item No.27.12.4 Supply, fixing, testing & commissioning of 80 mm size double flanged sluice valve of rating PN 1.6 with non-rising spindle , bronze/gun metal seat, ISI marked complete with nuts, bolts, washers, gaskets and confirming to IS 14846. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT)
07	DSR'2025, Item No.27.14.7 Supply, fitting and fixing of cast iron double flanged type non return valve as per IS:5312 with ISI mark of pressure rating PN 1.6 including flanges, rubber insertion, nut & bolts etc. complete. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR	DSR'2025, Item No.27.14.7 Proving, installation, testing & commissioning of non return valve of 150 mm size confirming to IS:5312 complete with rubber gasket, GI Bolts, nuts & washers etc. as required. (MAKE-- SANT, KIRLOSKAR,

Jung
18/3/26

	EQUIVALENT) 150mm dia	ADVANCE OR EQUIVALENT)
08	DSR'2025, Item No.27.14.5 Supply, fitting and fixing of cast iron double flanged type non return valve as per IS:5312 with ISI mark of pressure rating PN 1.6 including flanges, rubber insertion, nut & bolts etc. complete. (MAKE--SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT) 100mm dia	DSR'2025, Item No.27.14.5 Proving, installation, testing & commissioning of non return valve of 100 mm size confirming to IS:5312 complete with rubber gasket, GI Bolts, nuts & washers etc. as required. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT)
09	DSR'2025, Item No.27.11.4 Supply, fitting and fixing of cast iron double flanged slim seal wafer type Butterfly valve with EPDM rubber lined with liver operated as per IS 13095 with ISI mark of pressure rating PN 1.6 including flanges, rubber insertion, nut & bolts etc. complete. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT) 80mm dia	DSR'2025, Item No.27.12.4 Supply, fixing, testing & commissioning of 80 mm size Butterfly valve of rating PN 1.6 with bronze/gun metal seat duly ISI marked complete with nuts, bolts, washers, gaskets and confirming to IS 13095. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT)
10	DSR'2025, Item No.27.11.2 Supply, fitting and fixing of cast iron double flanged slim seal wafer type Butterfly valve with EPDM rubber lined with liver operated as per IS 13095 with ISI mark of pressure rating PN 1.6 including flanges, rubber insertion, nut & bolts etc. complete. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT) 50mm dia	DSR'2025, Item No.27.12.2 Supply, fixing, testing & commissioning of 50 mm size Butterfly valve of rating PN 1.6 with bronze/gun metal seat duly ISI marked complete with nuts, bolts, washers, gaskets and confirming to IS 13095. (MAKE-- SANT, KIRLOSKAR, ADVANCE OR EQUIVALENT)
11	DSR'2025, Item No.27.22 Supply, Installation, Testing and Commissioning of IPS 100 pressure switch along with required accessories complete. (Make-INDFOSS,DANFOSS)	DSR'2025, Item No.27.22 Providing & fixing pressure switch in M.S pipe line including connection etc as required. (Make-INDFOSS,DANFOSS)

All other terms and conditions remain unchanged.

Superintending Engineer (Civil)